

# Bayshore Subdivision History of Pipe Breaks

The Bayshore Subdivision has had a total of 25 recorded breaks over the past 22 years and at least 9 undocumented breaks. "Location" cited below is to closest nearby residence. The maintenance records prior to 2000 were documented in less detail than those in the past decade.

1	May 1, 2010	3823 W. 100th Avenue	Water was surfacing near the roadway required the utility pole to be shored up. The repair crew found two service lines that required repair. Approximately 225 sqft of lawn was replaced, and one small spruce tree was removed.
2	April 10, 2010	3431 Amber Bay Loop	3 mainline valves had to be shut down, resulting in a 3 hour shutdown of service. Approximately 230 sqft of lawn had to be replaced.
3	May 2, 2008	Bayshore & 100th Avenue	Water was surfacing at the intersection. The roadway had to be repaved right away to reduce impacts to traffic. Repairs lasted past 7PM.
4	April 17, 2007	Across the Street from 9941 Sitkalidak Lane	Dead end line required shutdown for repairs. The water was noticed to be surfacing to the roadway and draining to Lakeside Drive.
5	December 7, 2006	3420 Hooper Circle	Water was "bubbling" up from the ground. The repair was made at night.
6	February 10, 2006	10055 Goodnews Circle	Shutdown resulted in loss of service to 25 homes for over 6 hours from 2-8PM. Extended shutdown due to the repair proximity to gas line.
7	March 2, 2005	3790 Perenosa Circle	NE corner of the property got excavated, which required removal and replacement of 40 feet of chain link fence and an 8 foot by 15 foot concrete block planter.
8	January 23, 2005	Behind 3641 Hazen Circle, in Easement	Break at the main and service line. Extensive surface water flooded a back yard and required a vac-truck to remove the water.
9	March 3, 2004	3401 Kachemak Circle	Required tree removal from the greenbelt behind 3401 Kachemak Circle, and mild disruption to traffic along 100th Avenue. The lawn in the easement was replaced.
10	January 28, 2004	Between 3621 and 3641 Amber Bay Loop	2 day repair within greenbelt. Water repair required 1.5 hours of shutdown.
11	January 24, 2004	3401 Kachemak Circle	Break in line caused water shutdown for over 6 hours. Nearby low-lying basement was cited to have "a lot of water" which required a professional cleanup service. 5 greenbelt trees were removed.
12	November 7, 2002	10035 Goodnews Circle	2 Day repair - Pavement, Curb & Gutter, and front lawn area affected.
13	April 24, 2002	Behind 3551 Amber Bay Drive	3 Day Repair. Standing water complicated utility locates, resulting in disruption to electrical and communication lines. A 4' x 30' planter was damaged, and over 2,700 sqft of private and easement lawn had to be repaired.
14	December 6, 2001	3540 Amber Bay Loop	Service connection to 1 residence was damaged, and 24 feet of chain link fence had to be replaced and over 500 sqft of pave/patch easement lawn had to be repaired.
15	November 2, 1999	9941 Sitkalidak Circle	Break in a 6-inch main.
16	April 19, 1999	10205 Goodnews Circle	Break in an 8-inch main.
17	October 8, 1996	3311 Amber Bay Loop	Break in a 6-inch main.
18	January 8, 1996	10027 Marmot Circle	Break in a 6-inch main.
19	February 1, 1995	3640 Amber Bay Loop in Easement	Break in a 6-inch main.
20	January 31, 1995	3550 Amber Bay Loop	Break in a 6-inch main.
21	March 5, 1993	3440 Amber Bay Loop (greenbelt)	Break in a 6-inch main.
22	April 9, 1992	3790 Perenosa Circle (easement)	Break in an 8-inch main.
23	February 20, 1990	3750 Perenosa Circle	Break on a fire hydrant leg.
24	February 14, 1990	3530 Hooper Circle	Break in a 6-inch main.
25	February 10, 1988	3641 Hazen Circle	Break in a 6-inch main.

**U** Designates undocumented pipe breaks.

